

Insulation Checklist

- Items from framing checklist are complete.
- Baffles are installed at the exterior edge of the wall allowing for proper insulation coverage over the top plate.
- No gaps, voids, compression, or misalignment.
- Insulation is installed so that it will be in full contact with the air barrier (typically the sheet rock).
- Kraft faced batts are face-stapled.
- Insulation is split around plumbing and around electrical wires.
- Insulation is cut around and placed behind electrical outlets and plumbing.
- Reliefs are cut at blocking and ladder T's.
- Insulation is properly installed everywhere along the air barrier, or will easily be installed after drywall (check for spots difficult to insulate after drywall: underneath attic platform, etc.).
- Caulk has been used to seal the bottom-plate / sub-floor connection if no gasket (Sill-Seal) was used.