

East Hospital Survey

Current Motor Inventory

Facility	ID #	Description	Process	Manufacturer	Model #	NP Volts	NP Speed	Rated Amps	NP Eff.	Meas. Volts	Measured Amperage				kW	Frame Type	Enc.	Est. Eff.	Operating Hours / Yr	HP	Estimated kWh Per Year	Estimated Operating Cost Per Year
											A	B	C	Avg.								
East Hospital	1	Condenser Pump #5	☐	☐	☐	460	1760	☐	☐	☐	☐	☐	☐	☐	15.6	284T	ODP	89.4%	8,760	25	137,059	\$ 7,538
East Hospital	2	Condenser Pump #5	☐	☐	☐	460	1760	☐	☐	☐	☐	☐	☐	☐	15.6	284T	ODP	89.4%	8,760	25	137,059	\$ 7,538
East Hospital	3	Condenser Pump #5	☐	☐	☐	460	1760	☐	☐	☐	☐	☐	☐	☐	15.6	284T	ODP	89.4%	8,760	25	137,059	\$ 7,538
East Hospital	4	Condenser Pump #5	☐	☐	☐	460	1760	☐	☐	☐	☐	☐	☐	☐	15.6	284T	ODP	89.4%	8,760	25	137,059	\$ 7,538
East Hospital	5	Condenser Pump #5	☐	☐	☐	460	1760	☐	☐	☐	☐	☐	☐	☐	15.6	284T	ODP	89.4%	8,760	25	137,059	\$ 7,538
East Hospital	6	Condenser Pump #5	☐	GE	5KW324AL205	460	1760	☐	☐	☐	☐	☐	☐	☐	15.6	284T	ODP	89.4%	8,760	25	137,059	\$ 7,538
East Hospital	7	Air Pump HA7	☐	Magnatek	☐	230/460	1770	☐	93.0%	☐	☐	☐	☐	☐	30.1	326T	ODP	93.0%	8,760	50	263,506	\$ 14,493
East Hospital	8	AH #10	☐	Magnatek	☐	230/460	1780	☐	☐	☐	☐	☐	☐	☐	24.8	326T	ODP	90.2%	8,760	40	217,349	\$ 11,954
East Hospital	9	H25AH	☐	Magnatek	☐	230/460	1765	☐	91.7%	☐	☐	☐	☐	☐	30.5	324T	TEFC	91.7%	8,760	50	267,242	\$ 14,698
East Hospital	10	H25AH	☐	☐	☐	230/460	1765	☐	91.7%	☐	☐	☐	☐	☐	30.5	324T	TEFC	91.7%	8,760	50	267,242	\$ 14,698
East Hospital	11	H25AH	☐	☐	☐	230/460	1765	☐	91.7%	☐	☐	☐	☐	☐	30.5	324T	TEFC	91.7%	8,760	50	267,242	\$ 14,698
East Hospital	12	AH #1	☐	☐	☐	460	1654‡	☐	☐	☐	☐	☐	☐	☐	18.8	286T	TEFC	89.4%	8,760	30	164,470	\$ 9,046
East Hospital	13	AH #2	☐	☐	☐	460	1654‡	☐	☐	☐	☐	☐	☐	☐	18.8	286T	TEFC	89.4%	8,760	30	164,470	\$ 9,046
East Hospital	14	AH #3	☐	☐	☐	460	1654‡	☐	☐	☐	☐	☐	☐	☐	18.8	286T	TEFC	89.4%	8,760	30	164,470	\$ 9,046
East Hospital	15 †	Cooling Tower Motors	☐	Siemens	RCZCT	460	1773	☐	☐	☐	☐	☐	☐	☐	18.8	286T	TEFC	89.4%	8,760	30	164,470	\$ 9,046
East Hospital	16 †	Cooling Tower Motors	☐	Siemens	RCZCT	460	1773	☐	☐	☐	☐	☐	☐	☐	18.8	286T	TEFC	89.4%	8,760	30	164,470	\$ 9,046
East Hospital	17 †	Cooling Tower Motors	☐	Siemens	RCZCT	460	1770	☐	☐	☐	☐	☐	☐	☐	15.6	286T	TEFC	89.4%	8,760	25	137,059	\$ 7,538
East Hospital	18 †	Cooling Tower Motors	☐	☐	☐	460	1770	☐	☐	☐	☐	☐	☐	☐	15.6	286T	TEFC	89.4%	8,760	25	137,059	\$ 7,538
East Hospital	19 †	Cooling Tower Motors	☐	GE	5KS326AL205C	460	1770	☐	☐	☐	☐	☐	☐	☐	15.6	286T	TEFC	89.4%	8,760	25	137,059	\$ 7,538
East Hospital	20	#2 Chiller	☐	GE	5KS326AL205C	230/460	1765	☐	92.4%	☐	☐	☐	☐	☐	18.2	286T	ODP	92.4%	8,760	30	159,131	\$ 8,752
East Hospital	21	AH #18	☐	GE	5KS324AL205C	230/460	1780	☐	☐	☐	☐	☐	☐	☐	31.0	326T	ODP	90.2%	8,760	50	271,686	\$ 14,943
East Hospital	22	AH #19	☐	GE	5KS326AL205C	230/460	1780	☐	☐	☐	☐	☐	☐	☐	31.0	326T	ODP	90.2%	8,760	50	271,686	\$ 14,943
East Hospital	23	AH #21	☐	Marathon	Gould Pump	230/460	1780	☐	☐	☐	☐	☐	☐	☐	24.8	326T	ODP	90.2%	8,760	40	217,349	\$ 11,954
East Hospital	24	AH #22	☐	Marathon	Gould Pump	230/460	1780	☐	☐	☐	☐	☐	☐	☐	31.0	326T	ODP	90.2%	8,760	50	271,686	\$ 14,943
East Hospital	25 §	Pump #17	☐	Marathon	Gould Pump	230/460	1770	☐	83.5%	☐	☐	☐	☐	☐	26.8	324T	ODP	83.5%	8,760	40	234,789	\$ 12,913
East Hospital	26 §	Pump #1	☐	Lincoln	TF4679	230/460	1770	☐	92.0%	☐	☐	☐	☐	☐	24.3	324T	ODP	92.0%	8,760	40	213,097	\$ 11,720
East Hospital	27 §	Pump #15	☐	Marathon	☐	230/460	1770	☐	83.5%	☐	☐	☐	☐	☐	26.8	324T	ODP	83.5%	8,760	40	234,789	\$ 12,913
East Hospital	28	Pump #22	☐	☐	☐	230/460	1765	☐	92.4%	☐	☐	☐	☐	☐	30.3	324T	ODP	92.4%	8,760	50	265,218	\$ 14,587
East Hospital	29 §	Cooling Loop Pump #3	Pot Feeder	☐	☐	460	1760	☐	93.0%	☐	☐	☐	☐	☐	30.1	326T	ODP	93.0%	8,760	50	263,506	\$ 14,493
East Hospital	30	Condenser Pump #3	☐	☐	☐	230/460	1800	☐	92.4%	☐	☐	☐	☐	☐	18.2	286T	ODP	92.4%	8,760	30	159,131	\$ 8,752
																			Total HP	Total Annual kWh	Total Annual Cost	
																			1,085	5,900,530	\$ 324,529	

Notes/Assumptions:

- 1 Motor List Discount is 50%
- 2 Electricity Cost is \$0.055/kWh (includes demand charge)
- 3 75% Load unless otherwise given
- 4 ☐ = Data not available
- 5 § = Motor on Variable Frequency Drive
- 6 † = Two speed motor, more data necessary for accurate efficiency prediction
- 7 ‡ = Data is suspect, requires further investigation



Motors and Drives

August 12, 2008

East Hospital Survey

Motor Action Plan

Facility	ID #	Hp	Estimated Operating Efficiency	Estimated Repair Cost	Replacement Catalog #	Replacement Manufacturer	Replacement Model	Replacement Efficiency	Replacement List Cost	Replacement Actual Cost	Energy Savings (kWh)	Energy Savings (\$/yr.)	Payback (Years) Replace Now	Payback (Years) Replace at Failure	Immediate Action	Action Upon Failure
East Hospital	1	25	89.4%	\$ 571	M9935	GE	Ultra Series	94.1%	¤	\$ 1,081	6,442	\$ 354	3.1	1.4	None	Replace
East Hospital	2	25	89.4%	\$ 571	M9935	GE	Ultra Series	94.1%	¤	\$ 1,081	6,442	\$ 354	3.1	1.4	None	Replace
East Hospital	3	25	89.4%	\$ 571	M9935	GE	Ultra Series	94.1%	¤	\$ 1,081	6,442	\$ 354	3.1	1.4	None	Replace
East Hospital	4	25	89.4%	\$ 571	M9935	GE	Ultra Series	94.1%	¤	\$ 1,081	6,442	\$ 354	3.1	1.4	None	Replace
East Hospital	5	25	89.4%	\$ 571	M9935	GE	Ultra Series	94.1%	¤	\$ 1,081	6,442	\$ 354	3.1	1.4	None	Replace
East Hospital	6	25	89.4%	\$ 571	M9935	GE	Ultra Series	94.1%	¤	\$ 1,081	6,442	\$ 354	3.1	1.4	None	Replace
East Hospital	7	50	93.0%	\$ 909	M9917	GE	Ultra Series	94.7%	¤	\$ 1,918	4,480	\$ 246	7.8	4.1	None	Repair
East Hospital	8	40	90.2%	\$ 776	M9915	GE	Ultra Series	94.6%	¤	\$ 1,636	9,563	\$ 526	3.1	1.6	None	Replace
East Hospital	9	50	91.7%	\$ 1,095	M9917	GE	Ultra Series	94.7%	¤	\$ 1,918	8,017	\$ 441	4.3	1.9	None	Replace
East Hospital	10	50	91.7%	\$ 1,095	M9917	GE	Ultra Series	94.7%	¤	\$ 1,918	8,017	\$ 441	4.3	1.9	None	Replace
East Hospital	11	50	91.7%	\$ 1,095	M9917	GE	Ultra Series	94.7%	¤	\$ 1,918	8,017	\$ 441	4.3	1.9	None	Replace
East Hospital	12	30	89.4%	\$ 771	M9937	GE	Ultra Series	94.2%	¤	\$ 1,263	7,895	\$ 434	2.9	1.1	None	Replace
East Hospital	13	30	89.4%	\$ 771	M9937	GE	Ultra Series	94.2%	¤	\$ 1,263	7,895	\$ 434	2.9	1.1	None	Replace
East Hospital	14	30	89.4%	\$ 771	M9937	GE	Ultra Series	94.2%	¤	\$ 1,263	7,895	\$ 434	2.9	1.1	None	Replace
East Hospital	15 †	30	89.4%	†	-	-	-	†	†	†	†	†	†	†	-	-
East Hospital	16 †	30	89.4%	†	-	-	-	†	†	†	†	†	†	†	-	-
East Hospital	17 †	25	89.4%	†	-	-	-	†	†	†	†	†	†	†	-	-
East Hospital	18 †	25	89.4%	†	-	-	-	†	†	†	†	†	†	†	-	-
East Hospital	19 †	25	89.4%	†	-	-	-	†	†	†	†	†	†	†	-	-
East Hospital	20	30	92.4%	\$ 640	M9937	GE	Ultra Series	94.2%	¤	\$ 1,263	2,864	\$ 158	8.0	4.0	None	Repair
East Hospital	21	50	90.2%	\$ 909	M9917	GE	Ultra Series	94.7%	¤	\$ 1,918	12,226	\$ 672	2.9	1.5	None	Replace
East Hospital	22	50	90.2%	\$ 909	M9917	GE	Ultra Series	94.7%	¤	\$ 1,918	12,226	\$ 672	2.9	1.5	None	Replace
East Hospital	23	40	90.2%	\$ 776	M9915	GE	Ultra Series	94.6%	¤	\$ 1,636	9,563	\$ 526	3.1	1.6	None	Replace
East Hospital	24	50	90.2%	\$ 909	M9917	GE	Ultra Series	94.7%	¤	\$ 1,918	12,226	\$ 672	2.9	1.5	None	Replace
East Hospital	25 §	40	83.5%	\$ 776	M9915	GE	Ultra Series	94.6%	¤	\$ 1,636	26,062	\$ 1,433	1.1	0.6	Replace	-
East Hospital	26 §	40	92.0%	\$ 776	M9915	GE	Ultra Series	94.6%	¤	\$ 1,636	5,541	\$ 305	5.4	2.8	None	Repair
East Hospital	27 §	40	83.5%	\$ 776	M9915	GE	Ultra Series	94.6%	¤	\$ 1,636	26,062	\$ 1,433	1.1	0.6	Replace	-
East Hospital	28	50	92.4%	\$ 909	M9917	GE	Ultra Series	94.7%	¤	\$ 1,918	6,100	\$ 336	5.7	3.0	None	Repair
East Hospital	29 §	50	93.0%	\$ 909	M9917	GE	Ultra Series	94.7%	¤	\$ 1,918	4,480	\$ 246	7.8	4.1	None	Repair
East Hospital	30	30	92.4%	\$ 640	M9937	GE	Ultra Series	94.2%	¤	\$ 1,263	2,864	\$ 158	8.0	4.0	None	Repair

Total Annual kWh Savings	Total Annual Cost Savings	Average Payback	Average Payback
220,642	\$ 12,135	4.0	1.9

Notes/Assumptions:

- Motor list discount is 50%
- Electricity Cost is \$0.055/kWh (includes demand charge)
- ¤ = Data not available
- § = Motor on Variable Frequency Drive, assumed to be 75% loaded.
- Values in **RED** have less than 2 year payback All motors surveyed here will pay for themselves over the expected lifecycle (10 years)
- † = Two speed motor, more data necessary for accurate efficiency prediction.
- No Utility Rebates or Gov Incentives are included in this analysis. Incentives and rebates for new motor purchases will shorten payback periods and are more than likely available.
- Estimated Repair Cost and Replacement Actual Cost does not include cost of labor.
- Replacement motor costs are representative, can vary based on brand and vendor
- Estimated Efficiencies are from Motormaster+ 4.0 unless specified by nameplate data.
- Motor is assumed to be TEFC unless specified.



Motors and Drives

August 12, 2008