



Success with 2014 Florida Building Code,
Energy Conservation
Checklist for Builders & Trades

PLUMBING





PLUMBING

CHECKLIST: JOB READY

RECOMMENDED PRACTICES + CODE REFERENCE

✓ ✗ N/A

All walls separating conditioned and unconditioned spaces shall provide the required R-value, have a top plate,

1. **bottom plate and an exterior air barrier. RECOMMENDED: RIGID AIR BARRIER**

Code Reference: 2014 FBC, Energy Conservation Table 402.1.1: Insulation levels

All walls separating conditioned and unconditioned spaces have an interior air barrier.

2. **RECOMMENDED: RIGID AIR BARRIER**

Code Reference: 2014 FBC, Energy Conservation Table 402.4.1.1: Air barrier and insulation installation

3. **All dropped ceilings/soffits, shafts and chases are capped with an air barrier and air sealed.**

Code Reference: 2014 FBC, Energy Conservation Table 402.4.1.1: Air barrier and insulation installation

BUILDER VERIFICATION

✓ ✗

Stop work until details are corrected.

Proceed without corrections.

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Signature:

Date:



PLUMBING

CHECKLIST: JOB COMPLETE

RECOMMENDED PRACTICES + CODE REFERENCE	✓	✗	N/A
1. Cut all holes cleanly and no more than 1 inch larger than the penetrating object. Code Reference: 2014 FBC, Energy Conservation Table 402.4.1.1: Air barrier and insulation installation	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Air seal all penetrations between conditioned and unconditioned space. Use fire-stop systems where applicable. Code Reference: 2014 FBC, Energy Conservation Table 402.4.1.1: Air barrier and insulation installation	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
All walls separating conditioned and unconditioned spaces have an interior air barrier.			
3. RECOMMENDED: RIGID AIR BARRIER Code Reference: 2014 FBC, Energy Conservation Table 402.4.1.1: Air barrier and insulation installation	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do not install gas lighting systems that has a continuously burning pilot light. Code Reference: 2014 FBC, Energy Conservation 404.1.1: Equipment lighting systems	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. When following the prescriptive path, insulate hot water pipes to at least R-3. Code Reference: 2014 FBC, Energy Conservation 403.4.2: Hot water pipe insulation	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Install inlet and outlet heat traps on storage water tanks. Code Reference: 2014 FBC, Energy Conservation 403.4.3: Heat Traps	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

CERTIFICATION

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations.

Name:

Company:

Signature: