



Success with Louisiana Energy Code

Checklist for Builders/Trades & Code Officials

FOUNDATION





FOUNDATION CHECKLIST: JOB READY

RECOMMENDED PRACTICES + CODE REFERENCE

✓ ✗ N/A

- | | | | |
|---|--------------------------|--------------------------|--------------------------|
| Construction documents (e.g., building plans, technical documents, supporting performance compliance reports)
1. were received.
Code Reference: None | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| The construction documents detail the envelope will have a continuous air barrier.
2. <i>RECOMMENDED: RIGID AIR BARRIER</i>
Code Reference: 2009 IRC N1102.4: Air leakage | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| All walls separating conditioned and unconditioned spaces will allow for required R-value.
3. Code Reference: 2009 IRC Table N1102.1: Insulation and fenestration requirements | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

BUILDER VERIFICATION

✓ ✗

Stop work until details are corrected.

Proceed without corrections.

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Signature:

Date:



FOUNDATION CHECKLIST: JOB COMPLETE

RECOMMENDED PRACTICES + CODE REFERENCE

✓ ✗ N/A

- | | | | |
|--|--------------------------|--------------------------|--------------------------|
| 1. For crawl spaces, install 6-mil poly sheeting to overlap and extend up foundation walls at least 6".
Code Reference: 2009 IRC N1102.2.9: Crawl space walls | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. Damp proof the exterior of all below-grade walls.
Code Reference: 2009 IRC R406: Foundation damp proofing | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. Install a drainage system along entire foundation footing of below-grade walls.
Code Reference: 2009 IRC R405.1: Foundation drainage | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4. For exterior insulation, install without gaps, voids, misalignment or compression, and with a rigid, opaque and weather-resistant protective covering.
Code Reference: 2009 IRC R318.4: Foam plastic protection | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5. For exterior insulation, install to meet Louisiana Energy Code insulation levels.
Code Reference: 2009 IRC Table N1102.1: Insulation and fenestration requirements | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

CERTIFICATION

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Name:

Company:

Signature: