



Success with Louisiana Energy Code

Checklist for Builders/Trades & Code Officials

PLUMBING





PLUMBING CHECKLIST: JOB READY

RECOMMENDED PRACTICES + CODE REFERENCE

✓ ✗ N/A

- | | | | |
|---|--------------------------|--------------------------|--------------------------|
| 1. For walls separating conditioned and unconditioned spaces, framing allows for the required R-value, has a top plate, bottom plate and an exterior air barrier.
Code Reference: 2009 IRC Table N1102.1: Insulation and fenestration requirements | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. For walls that will not have an interior finish and are separating conditioned and unconditioned spaces, wall cavities are insulated and an interior air barrier is installed.
Code Reference: 2009 IRC Table N1102.4.2: Air barrier and insulation inspection | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. All dropped ceilings/soffits, shafts and chases are capped with an air barrier and an approved air sealing material.
Code Reference: 2009 IRC Table N1102.4.2: Air barrier and insulation inspection | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

BUILDER VERIFICATION

✓ ✗

Stop work until details are corrected.

Proceed without corrections.

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Signature:

Date:



PLUMBING

CHECKLIST: JOB COMPLETE

RECOMMENDED PRACTICES + CODE REFERENCE

✓ ✗ N/A

- | | | | |
|--|--------------------------|--------------------------|--------------------------|
| 1. Cut all holes cleanly and no more than 1" larger than the penetrating object.
Code Reference: 2009 IRC Table N1102.4.2: Air barrier and insulation inspection | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. Air seal all penetrations between conditioned and unconditioned spaces. Use fire-rated sealants where applicable.
Code Reference: 2009 IRC Table N1102.4.2: Air barrier and insulation inspection | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| For walls that will not have an interior finish and are separating conditioned and unconditioned spaces, insulate wall cavities and install an interior air barrier. <i>RECOMMENDED: RIGID AIR BARRIER</i>
Code Reference: 2009 IRC Table N1102.4.2: Air barrier and insulation inspection | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4. Hot water pipes must be insulated to R-2 when required.
Code Reference: 2009 IRC N1103.4: Circulating hot water systems | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

CERTIFICATION

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Name:

Company:

Signature: