



Success with 2015 IECC Northeast & Mid-Atlantic
Checklist for Builders & Trades

PLUMBING





PLUMBING

CHECKLIST: JOB READY

RECOMMENDED PRACTICES + CODE REFERENCE

✓ ✗ N/A

For walls separating conditioned and unconditioned space, framing allows for the required R-value, has a top

1. **plate, bottom plate and an exterior air barrier. *RECOMMENDED: RIGID AIR BARRIER***

Code Reference: 2015 IECC Table R402.4.1.1: Air barrier and insulation installation

For walls that will not have an interior finish and are separating conditioned and unconditioned spaces, wall

2. **cavities are insulated and an interior air barrier is installed. *RECOMMENDED: RIGID AIR BARRIER***

Code Reference: 2015 IECC Table R402.4.1.1: Air barrier and insulation installation

All dropped ceilings/soffits, shafts and chases are capped with an air barrier and air sealed.

3. ***RECOMMENDED: RIGID AIR BARRIER***

Code Reference: 2015 IECC Table R402.4.1.1: Air barrier and insulation installation

BUILDER VERIFICATION

✓ ✗

Stop work until details are corrected.

Proceed without corrections.

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Signature:

Date:



PLUMBING

CHECKLIST: JOB COMPLETE

RECOMMENDED PRACTICES + CODE COMPARISON

✓ ✗ N/A

- | | | | |
|---|--------------------------|--------------------------|--------------------------|
| <p>1. Cut all holes cleanly and no more than 1 inch larger than the penetrating object.
Code Reference: 2015 IECC Table R402.4.1.1: Air barrier and insulation installation</p> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <p>2. Air seal all penetrations between conditioned and unconditioned space. Use fire-rated sealants where applicable.
Code Reference: 2015 IECC Table R402.4.1.1: Air barrier and insulation installation</p> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <p>For walls that will not have an interior finish and are separating conditioned and unconditioned spaces, insulate wall cavities and install an interior air barrier. <i>RECOMMENDED: RIGID AIR BARRIER.</i>
Code Reference: 2015 IECC Table R402.4.1.1: Air barrier and insulation installation</p> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <p>4. Do not install a gas lighting systems that has a continuously burning pilot light.
Code Reference: 2015 IECC R404.1.1: Lighting equipment</p> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <p>5. Hot water pipes must be insulated to minimum R-3 when required.
Code Reference: 2015 IECC R403.5.3: Hot water pipe insulation</p> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

CERTIFICATION

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Name:

Company:

Signature: