

Success with 2009 IECC:
Checklists for Code Officials
PLAN REVIEW



CHECKLIST: PLAN REVIEW

Utilize this checklist during the plan review period before permits are issued. It may be used to document items to be corrected.		✓	✗	N/A
FRAMING + AIR SEALING				
1	All walls separating conditioned and unconditioned space will allow for required R-value and will have a top plate, bottom plate and an exterior air barrier.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			
2	All walls separating conditioned and unconditioned spaces that will not have an interior finish are noted on the plans and sections and specify an interior air barrier.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			
3	Attic platform details are included and allow for full amount of required insulation levels underneath.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.1.1: Insulation levels	Location of Problem:		
	<i>Notes:</i>			
4	Corner and header architectural details are included and allow for insulation installation.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			
5	Cantilever floors have insulation that completely fills the cavity or will maintain permanent contact with the subfloor and encapsulates the insulation with an exterior rigid air barrier and air sealing.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			
HVAC				
6	ACCA Manual J Load calculations or an equivalent method are accurate and complete for the dwelling unit.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IRC M1401.3: Equipment Sizing	Location of Problem:		
	<i>Notes:</i>			

CHECKLIST: PLAN REVIEW

Utilize this checklist during the plan review period before permits are issued. It may be used to document items to be corrected.		✓	✗	N/A
HVAC				
7	Specified HVAC equipment is selected based on the ACCA Manual S or other approved equipment selection method.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IRC M1401.3:	Location of Problem:		
	<i>Notes:</i>			
ELECTRICAL				
8	Specified bath fans will exhaust at least 50 CFM intermittently or 20 CFM continuously when installed and meet the efficacy requirements.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IRC M1507.3: Exhaust fan rate	Location of Problem:		
	<i>Notes:</i>			
9	Specified recessed lighting fixtures are insulation-contact rated (IC) and must meet air leakage requirements.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC 402.4.5: Recessed lighting	Location of Problem:		
	<i>Notes:</i>			
INSULATION				
10	All insulation levels shown on drawings will meet 2009 IECC insulation levels.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.1.1: Insulation levels	Location of Problem:		
	<i>Notes:</i>			

CODE OFFICIAL VERIFICATION	
Name	
Company	
Phone Number	
Email Address	
Date of Review	
Permit/Job Number	
Permit Type	