

Success with 2009 IECC:
Checklists for Code Officials
ROUGH-IN



CHECKLIST: ROUGH-IN

Utilize this checklist when completing an inspection on-site. By completing the checklist in its entirety, you will be providing a written record of what is installed properly and what needs to change to comply.		✓	✗	N/A
FRAMING + AIR SEALING				
1	All walls separating conditioned and unconditioned space allow for required R-value and have a top plate, bottom plate and an exterior air barrier.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			
2	All walls separating conditioned and unconditioned spaces that will not have an interior finish have an interior air barrier.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			
3	Attic platforms allow for full amount required insulation levels underneath.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.1.1: Insulation levels	Location of Problem:		
	<i>Notes:</i>			
4	All corners and headers framed for insulation installation.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			
5	All dropped ceilings/soffits, shafts and chases are capped with an air barrier and sealed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			
6	All floor systems within the conditioned envelope have an air-sealed band or blocking separating conditioned and unconditioned space.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			

CHECKLIST: ROUGH-IN

Utilize this checklist when completing an inspection on-site. By completing the checklist in its entirety, you will be providing a written record of what is installed properly and what needs to change to comply.		✓	✗	N/A
FRAMING + AIR SEALING				
7	Cantilever floors have insulation that completely fills the cavity or will maintain permanent contact with the subfloor and encapsulates the insulation with an exterior rigid air barrier and air sealing.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	Notes:			
8	All gaps and voids between conditioned and unconditioned spaces are air sealed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	Notes:			
9	There is backer rod, caulk or low expansion foam around windows and doors.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	Notes:			
10	There is air sealing between the bottom plate of the exterior wall and the subfloor.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	Notes:			
11	All penetrations between conditioned and unconditioned spaces are air sealed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	Notes:			

CHECKLIST: ROUGH-IN

Utilize this checklist when completing an inspection on-site. By completing the checklist in its entirety, you will be providing a written record of what is installed properly and what needs to change to comply.		✓	✗	N/A
HVAC				
12	No building cavities being used as a part of the supply ducts.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC 403.2.3: Building cavities	Location of Problem:		
	<i>Notes:</i>			
13	All duct terminations sealed to the subfloor and all HVAC penetrations through the building envelope are air sealed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			
14	All HVAC components are sealed at the joints and seams.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC 403.2.2: Duct sealing, 2009 IRC M1601.4.1: Duct sealing	Location of Problem:		
	<i>Notes:</i>			
15	All supply duct work in unconditioned attics is insulated to R-8. All other duct work outside of conditioned space is insulated to R-6.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC 403.2.1: Duct insulation, 2009 IRC M1601.4.5: Duct insulation	Location of Problem:		
	<i>Notes:</i>			
16	All mechanical piping that carries fluids above 105°F or below 55°F is insulated to at least R-3.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC 403.3: Mechanical pipe insulation	Location of Problem:		
	<i>Notes:</i>			
17	If duct leakage testing is complete, results meet 2009 IECC compliance levels.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC 403.2.2: Duct sealing, 2009 IRC M1601.4.1: Duct sealing	Location of Problem:		
	<i>Notes:</i>			

CHECKLIST: ROUGH-IN

Utilize this checklist when completing an inspection on-site. By completing the checklist in its entirety, you will be providing a written record of what is installed properly and what needs to change to comply.		✓	✗	N/A
ELECTRICAL				
18	Recessed lighting fixtures are insulation-contact rated (IC) and meet air leakage requirements	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC 402.4.5: Recessed lighting	Location of Problem:		
	<i>Notes:</i>			
PLUMBING				
19	Hot water pipes listed in R403.4.2 are insulated to at least R-3.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC 403.4: Circulating hot water system	Location of Problem:		
	<i>Notes:</i>			
INSULATION				
20	All installed insulation meets 2009 IECC insulation levels.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.1.1: Insulation levels	Location of Problem:		
	<i>Notes:</i>			
21	For vented attics, wind baffles are installed on top of all exterior walls, leaving room for insulation over top plates and ventilation above.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.1.1: Insulation levels, 2009 IECC 402.2.3: Baffles, 2009 IRC R806.3: Attic ventilation	Location of Problem:		
	<i>Notes:</i>			
22	For exterior insulation, install without gaps, voids, misalignment or compression and with a rigid, opaque and weather resistant protective covering.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC 303.2.1: Foundation insulation protection	Location of Problem:		
	<i>Notes:</i>			

CHECKLIST: ROUGH-IN

Utilize this checklist when completing an inspection on-site. By completing the checklist in its entirety, you will be providing a written record of what is installed properly and what needs to change to comply.		✓	✗	N/A
INSULATION				
23	Insulation is installed to fill the cavity between conditioned and unconditioned space without gaps, voids, misalignments or compression.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC 303.2: Insulation installation, 2009 IECC Table 402.1.1: Insulation Levels	Location of Problem:		
	<i>Notes:</i>			
24	Insulation is cut and split around blocking, plumbing, HVAC and electrical components.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Code Reference: 2009 IECC Table 402.4.2: Air barrier and insulation installation	Location of Problem:		
	<i>Notes:</i>			

CODE OFFICIAL VERIFICATION	
Name	
Company	
Phone Number	
Email Address	
Date of Review	
Permit/Job Number	
Permit Type	