



Success with 2012 NC Energy Conservation
Code in North Carolina:
Checklists for Builders

FOUNDATION





JOB READY: FOUNDATION

Success with 2012 NC Energy Conservation Code in North Carolina for Builders



N/A



1. Work site is clean and construction materials are properly stored before proceeding.

Builder Verification



Stop work until details are corrected.



Proceed without corrections.

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Signature

Date



JOB COMPLETE: FOUNDATION

Success with 2012 NC Energy Conservation Code in North Carolina for Builders



N/A



1. For crawl spaces, install poly sheeting that is at least 6-mil thickness and overlaps at least 12 inches.



2. Damp proof the exterior of all below-grade walls.



3. Install a drainage system along entire foundation footing of below-grade walls.



4. Install exterior insulation without gaps, voids, misalignments or compression and with a rigid, opaque and weather-resistant protective covering.



5. Install exterior insulation to meet the NC 2012 Energy Conservation Code.



6. Ensure work site is clean and construction materials are properly stored before proceeding.

Certification

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Name

Company

Signature