

# SUCCESS WITH 2012 IECC TEXAS & OKLAHOMA

Recommended Practices for Optimized Energy Savings  
*for Builders & Trades*



## FOUNDATION





## JOB READY FOUNDATION

## SUCCESS WITH 2012 IECC CODE

✓ ✗ N/A

1. Work site is clean and construction materials are properly stored before proceeding.

### Builder Verification

✓ ✗

Stop work until details are corrected.

Proceed without corrections.

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Signature

Date



## JOB COMPLETE FOUNDATION

## SUCCESS WITH 2012 IECC CODE

✓    ✗    N/A

- |                          |                          |                          |  |
|--------------------------|--------------------------|--------------------------|--|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 1. For crawlspaces, install 6-mil poly sheeting to overlap and extend up foundation walls at least 6 inches.   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 2. Damp proof the exterior of all below-grade walls.   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 3. Install a drainage system along entire foundation footing of below-grade walls.   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 4. For exterior insulation, install without gaps, voids, misalignment or compression and with a rigid, opaque and weather resistant protective covering. |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 5. For exterior insulation, install to meet 2012 IECC insulation levels.   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 6. Ensure work site is clean and construction materials are properly stored before proceeding.   |

### Certification

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Name

Company

Signature



## CODE COMPARISON FOUNDATION

## SUCCESS WITH 2012 IECC CODE

### Job Ready

<b>1</b>	None
----------	------

### Job Complete

<b>1</b>	<b>2012 IECC 402.2.10: Crawl space walls</b>
<b>2</b>	<b>2012 IRC R406: Foundation damp proofing</b>
<b>3</b>	<b>2012 IRC R405.1: Foundation drainage</b>
<b>4</b>	<b>2012 IECC 303.2.1: Foundation insulation protection</b>
<b>5</b>	<b>2012 IECC Table 402.1.1: Insulation levels, 2012 IECC 402.2.9 Slab-on-grade floors 2012 IECC 402.2.8 Basement walls</b>
<b>6</b>	None