



Success with 2012 IECC Nevada  
*Checklist for Builders & Trades*

# PLUMBING





# PLUMBING

## CHECKLIST: JOB READY

### RECOMMENDED PRACTICES + CODE REFERENCE

✓ ✗ N/A

- |  |                          |                          |                          |
|--|--------------------------|--------------------------|--------------------------|
| <b>For walls separating conditioned and unconditioned space, framing allows for the required R-value, has a top plate, bottom plate and an exterior air barrier.</b><br>Code Reference: 2012 IECC Table R402.1.1: Insulation levels  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>For walls that will not have an interior finish and are separating conditioned and unconditioned spaces, insulate wall cavities and install an interior air barrier, sealed at all seams and edges(e.g. behind bath tub, fireplace, stairs).</b><br>Code Reference: 2012 IECC Table R402.4.1.1: Air barrier and insulation installation | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>All dropped ceilings/soffits, shafts and chases are capped with an air barrier and air sealed.</b><br>Code Reference: 2012 IECC Table R402.4.1.1: Air barrier and insulation installation   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

### BUILDER VERIFICATION

✓ ✗

Stop work until details are corrected.

Proceed without corrections.

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_



# PLUMBING

## CHECKLIST: JOB COMPLETE

### RECOMMENDED PRACTICES + CODE REFERENCE

✓ ✗ N/A

- |    |  |                          |                          |                          |
|----|--|--------------------------|--------------------------|--------------------------|
| 1. | <b>Cut all holes cleanly and no more than 1 inch larger than the penetrating object.</b><br>Code Reference: 2012 IECC Table R402.4.1.1: Air barrier and insulation installation  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. | <b>Air seal all penetrations between conditioned and unconditioned space. Use fire-rated sealants where applicable.</b><br>Code Reference: 2012 IECC Table R402.4.1.1: Air barrier and insulation installation   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. | <b>For walls that will not have an interior finish and are separating conditioned and unconditioned spaces, insulate wall cavities and install an interior air barrier, sealed at all seams and edges (e.g. behind bath tub, fireplace, stairs).</b><br><b>RECOMMENDED: RIGID AIR BARRIER</b><br>Code Reference: 2012 IECC Table R402.4.1.1: Air barrier and insulation installation | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4. | <b>Do not install gas lighting systems that has a continuously burning pilot light.</b><br>Code Reference: 2012 IECC R404.1.1: Equipment lighting systems  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5. | <b>Hot water pipes must be insulated to R-3 when required.</b><br>Code Reference: 2012 IECC R403.4: Hot water pipe insulation  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

### CERTIFICATION

The sub-contractor who signs and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other organizations. The intent of this form is to ensure job sites are ready before beginning work.

Name:

Company:

Signature: